



CORRIGENDUM 1
Dated – 18.06.2024

TENDER PERIOD FROM 31.05.2024 TO 24.06.2024 UPTO 02:00 PM

PRE-BID MEETING DATED 11.06.2024 AT 11:30 AM

OPENING OF TECHNICAL BID ON 24.06.2024 AT 03:00 PM

CORRIGENDUM- I

“Tender for Signages & allied works for Baroda Apex Academy Building, Law Garden, Ahmedabad, Gujarat” and pre-bid meeting held on 11.06.2024. In this regard, we issue clarification on certain queries raised by Vendors which is given as under:

SI No.	Tender clause	Bidder's Query	Bank's Response (Please Read as)
	BOQ item No 2	<p>SS powder coated letters without Led lights:</p> <p>Supply and fixing of 18 gauge Stainless Steel plates with water jet cutting of grade 304 signage of required size and letters duly bordered . painted of as per required colour/ approved colour (powder coated)) of approved brand and filling with required matt/ mirror finish polish on base and border with shining polish of required shade and colour and duly fixed with required nos of rawls plugs stainless steel screw/ double side tape of 3M make/ nut bolt/ spacer required nos of holes, wherever required complete as per direction of Unit In charge.</p> <p>SS letters : Stainless Steel (304), SS Company : Jindal or equivalent, Material Thickness: 1 mm, Finish Type: Polished/Brushed, Letter Type: Hollow, Letter Depth: 13 mm , Mounting hardware : Studs, Powder coated letters as per preferred color. (BOB Name with logo in front elevation at 8/9th floor) The rate shall be inclusive of scaffolding /lift/ jhula safety tools etc. (Up to all floor & all level for outer signage)</p>	<p>SS powder coated letters without Led lights:</p> <p>Supply and fixing of 18 gauge Stainless Steel plates with water jet cutting of grade 304 signage of required size and letters duly bordered . painted of as per required colour/ approved colour (powder coated)) of approved brand and filling with required matt/ mirror finish polish on base and border with shining polish of required shade and colour and duly fixed with required nos of rawls plugs stainless steel screw/ double side tape of 3M make/ nut bolt/ spacer required nos of holes, wherever required complete as per direction of Unit In charge.</p> <p>SS letters: Stainless Steel (304), SS Company: Jindal or equivalent, Material Thickness: 1 mm, Finish Type: Polished/Brushed, Letter Type: Hollow, Letter Depth: 13 mm, Mounting hardware: Studs, Powder coated letters as per preferred color. (BOB Name with logo in front elevation at 8/9th floor) The rate shall be inclusive of scaffolding up to 12 meter, lead, lift up to terrace level / tools etc. (Up to all floor & all level)</p>

1. Bidders are advised to consider and confirm the above points while submitting the bids.
2. The above shall be complementary in contents with the existing terms and conditions of the Tender/Bid unless otherwise explicitly superseded. All other terms and conditions of the Tender/Bid shall remain unchanged.
3. This Corrigendum – I shall form part of the Bid/Tender.
4. The bidders have to submit “Unconditional Bid”. Conditional bids are liable to be rejected.
5. The last date for submission of bid through online portal is 24.06.2024 upto 2:00 PM

Date: 18.06.2024
Place: Gandhinagar

The Head
Apex Academy