



**Corrigendum No-1 dated 17.10.2024**

|              |  |
|--------------|--|
| E-Tender No. | <b>BCC/FM/SKC/116/T-01</b>   |
| Details      | E- TENDER FOR PROPOSED CIVIL, INTERIOR FURNISHING, FIRE FIGHTING, ELECTRICAL & HVAC WORK FOR BANK OF BARODA AT 1 <sup>st</sup> FLOOR, BARODA SUN TOWER, C 34, G BLOCK, BANDRA KURLA COMPLEX, BANDRA EAST, MUMBAI - 400051. |

| <b>Sr. No.</b> | <b>Query</b>  | <b>Reply / Amendment</b>  |
|----------------|---|---|
| 1.             | Length of SWR Pipes   | External connections are already established (not included in scope of work) - Tender quantities only pertain to internal toilet plumbing lines / connecting lines. Bidders are requested to visit the site and assess the requirement.   |
| 2.             | Look and feel of reception table, conference table, cabin tables.               | During Pre-Bid meeting, a comprehensive walkthrough of the office project was shared. Bidders can obtain 3D views from Project Architect, if required.  |
| 3.             | Cat 6 cable make  | D-Link / Delton / Avywa / AMP Already given on page 117 of tender.  |
| 4.             | Dismantling work.   | Minor quantities of dismantling works are involved in this project. Bidders are requested to visit the site and assess the requirement.   |
| 5.             | Basic Rate of Granite   | ₹200/- per sq.ft  |
| 6.             | Basic Rate of Toilet Flooring & Dado  | ₹70/- per sq.ft   |
| 7.             | Item no 51 & 52<br>(Grid Ceiling, Light Weight Calcium Silicate Ceiling)        | It is a single Line Item. Unit of measurement is Sq.Mtrs  |
| 8.             | Item no 54 & 55<br>(Polymer Based Soffit Ceiling)                               | It is a single Line Item. Unit of measurement is Sq.Mtrs`   |
| 9.             | Item 71<br>(Absorb Wool For Acoustic Partition/ Panelling)                      | This Item is not a Tender Line item.<br>This specification applies to the supply and installation of absorb wool for partition and panelling works up to slab level. Bidder shall ensure absorb wool is installed in accordance with this instructions. Absorb wool shall be fitted snugly into partitions and panelling. No additional payment will be made for absorb wool. All partition and panelling cost are to be included with cost of absorb wool, as specified. |
| 10.            | Whether only empanelled contractors are eligible to submit bids for this tender | No. This is an Open Tender.   |
| 11.            | Page No.38 B Financial to be read as  | The Bidder must have registered a Turnover of ₹81.00 Lacs or above.   |
| 12.            | BOQ Item No.45  | Unit of Measurement is "Numbers"  |

**All the other terms and conditions of the tender will remain unchanged.**

- All bidders are advised to consider the above points while submitting the financial bids.
- The above shall be complementary in contents with the existing terms and conditions of the tender except otherwise explicitly superseded. Other terms and conditions of the tender shall remain unchanged. Bidders have to meet requisite criteria laid down in the tender for qualification.
- This addendum/corrigendum shall form part of the tender i.e. contract agreement. The same shall be treated as acceptance of those conditions without any modifications and submitted along with the Tender bid. Non acceptance of the Addendum by the Bidder or adding any other condition shall be treated as conditional Tender and price bid of such Tenderers shall not be opened.

The last date of online submission of the Tender bids will remain unchanged i.e 25.10.2024 upto 3.30 PM. Bidders are advised to refer/check Bank's website for any additional instruction/addendum/corrigendum before tender submission time.

General Manager  
Facilities Management  
Baroda Corporate Centre  
Bank of Baroda

**17.10.2024**